



**GENERAL NOTES:**

1. ANY VARIATION OR DEVIATION FROM THIS STANDARD REQUIRES PREVIOUS APPROVAL PRIOR TO INSTALLATION FROM CUSTOMER SERVICE FIELD SECTION.
2. METER PIT MUST BE INSTALLED IN LANDSCAPED AREA. PRIOR APPROVAL REQD FOR INSTALLATIONS IN ROADWAYS, DRIVEWAYS OR SIDEWALKS. ROAD LIDS OR OTHER SPECIAL MODIFICATIONS MAY BE REQD.
3. CURB STOP SHALL BE 24 INCHES FROM INLET SIDE OF METER PIT, LOCATED IN LANDSCAPED AREA IF POSSIBLE. WITH PRIOR APPROVAL OF METER INSPECTOR, CURB STOP MAY BE PLACED BENEATH PAVED AREA UNDER ROADWAY BOX, BUT NOT IN A PARKING AREA.
4. ALL METER PITS SHALL BE FURNISHED WITH CI METER PIT LID WITH 7 1/2 INCH  $\phi$  x 3/4 INCH DEEP RECESS AND 2 INCH  $\phi$  CENTER HOLE FOR ITRON ERT, PLUS THREE DRAIN HOLES IN RECESSED AREA.
5. ALL METER PITS SHALL BE FURNISHED WITH PLASTIC FROST LID WITH 3 INCH DEEP PAN, FIVE DRAIN HOLES, LIFTING HANDLE, AND SLOT FOR ERT WIRE RUNNING FULL DEPTH OF LIP.
6. METER PIT SHALL BE CONSTRUCTED OF A COMBINATION OF CONC RINGS WITH A TOTAL HEIGHT OF 48 INCHES (SECTION 6.27). ADJUSTMENT RINGS OF APPROVED PLASTIC OR CONC SHALL BE INSERTED BETWEEN TOP RING AND DOME. RINGS MUST BE 2 INCH, 3 INCH, 4 INCH, OR 6 INCH HEIGHT. NO CONC FLOOR ALLOWED IN METER PITS. PLASTIC METER PITS ARE NOT PERMITTED. PIT SHALL BE INSTALLED TO MAINTAIN PIT LID 1/2 INCH BELOW FINISHED GRADE.
7. NO BENDS PERMITTED IN SERVICE LINE BETWEEN TAP AND 5 FT BEYOND OUTLET SIDE OF METER PIT. NO CHANGES IN PIPE  $\phi$  OR CONNECTIONS OF ANY TYPE ARE PERMITTED IN THE SERVICE LINE UNTIL 5 FT OR MORE FROM THE OUTLET SIDE OF THE METER PIT.
8. METER SHALL BE FURNISHED WITH ELECTRONIC DIGITAL REGISTER OR ELECTRONIC ENCODED REGISTER AND AN ITRON PIT ERT. IN SPECIAL CASES, A REMOTE ERT MAY BE REQD, MOUNTED ON A NEARBY BUILDING OR POST.

## DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204  
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

## OUTSIDE SETTING FOR 3/4" & 1" METERS

Scale: <i>NONE</i>	Date: <i>AUGUST 1995</i>
--------------------	--------------------------

Drawn: C.B.B. Tr:      Ck:     

Approved: [Signature] Dr. 127 No. 35